J0500–0494	B

REL NO	LTR	NO	REVISION	ZONE	DR	CHKR	APPROVED	DATE
–	–	1	1ST RELEASE	–	SC	LS	CL	29–JUL–05



	Model	Engine	Alternator	Ambient Temp.	Open Bed (kg)		Open Bed with Fuel Tank (kg)		Tank (Litres)
					Dry Wt.	Wet Wt.	Dry Wt.	Wet Wt.	
50Hz	C1100 D5	QST30 G4	HC6K	40°C	7488	7768	8716	10416	1700
60Hz	C1000 D6	QST30 G4	HC6J	40°C	7488	7768	8716	10416	1700





METRIC DWG

AUTOCAD DWG

DO NOT SCALE PRINT

ANG TOL ±1°

DRAWN TO SCALE OF 1/40

TOLERANCE UNLESS OTHERWISE SPECIFIED

	mm		Inch	
DIM	X ±1 .X ±.5 .XX±.25			
HOLE	0.09–4.99	+0.15/–0.08	.004–.200	+.006/–.003
	5.00–9.99	+0.20/–0.10	.201–.421	+.008/–.004
	10.00–17.49	+0.25/–0.13	.422–.703	+.010/–.005
	17.50–24.99	+0.30/–0.13	.704–.999	+.012/–.005

SIM TO – –

COPIED FROM – –

THIRD ANGLE PROJECTION

THIS DOCUMENT IS THE PROPERTY OF CUMMINS POWER GENERATION. IT CONTAINS PROPRIETARY AND CONFIDENTIAL INFORMATION WHICH MUST NOT BE DUPLICATED, USED OR DISCLOSED OTHER THAN AS EXPRESSLY AUTHORIZED BY CUMMINS POWER GENERATION OR ITS REPRESENTATIVE

FOR INTERPRETATION OF DIMENSIONING AND TOLERANCING, SEE ANSI Y14.5M–1982

QTY	ITEM	PART NO.	DWG SIZE	DESCRIPTION OR MATERIAL	REF DES

	NAME	DATE
DR	S.CHUA	29–JUL–05
CHKR ☒ MFG ☐	L.SNG	29–JUL–05
APPROVED	C.LIM	29–JUL–05

MODEL FIRST USED ON XXXX

SITE CODE PGS

CUMMINS POWER GENERATION
44 PIONEER SECTOR 2
SINGAPORE 628395

TITLE GENSET OUTLINE

DWG NO. J0500–0494

SHEET 1 OF 1

DWG SIZE B

PGS REF: